



**ADDENDUM NO. 2
WATER MAIN BUILDING
REQUEST FOR BIDS #11-1753
November 1, 2010**

Acknowledge receipt of this addendum by inserting its number in the Proposal Form. The contents of this addendum are to be covered in the bids and in closing the Contract will become a part thereof. Changes noted herein affect only the specific words in paragraphs mentioned and the balance of the Drawings and/or Specifications remains in full force.

GENERAL:

CLARIFICATION: The requirement for filling out the Recycled Products Schedule in the bid form has been eliminated. Using products with recycled content is still a desire of this project

CLARIFICATION of shut down and temporary water supply.

The sequencing of work will require coordination with the Portland Water Bureau and the Zoo. No shutdown of the water system to the Zoo will be allowed.

The Water Bureau will provide a temporary service that will provide enough volume and pressure that fire service will be adequate. Standby water tanker **will not** be required

The temporary service will be limited to a maximum of 6 hours in length from the hours of 6 PM until 4 AM.

DRAWINGS:

SHEET C02

CLARIFICATION: The driveway must be kept open for emergency vehicles at all times. The contractor is to schedule the work to allow access and have metal plates available if open trenching is occurring.

SPECIFICATIONS:

00 21 13 Instructions to Bidders

DELETE Paragraph 12 and **REPLACE** with the following:

“Metro reserves the right to make award of this Contract to the lowest responsible bidder submitting the lowest responsive bid, which shall include the base bid plus any owner selected alternates.



In determining the lowest responsive bid and responsible bidder, Metro shall, for the purpose of awarding the Contract, add a percent increase on the bid of a non-resident bidder, equal to the percent, if any, of the preference given to that non-resident bidder in the state in which that bidder resides. For purposes of determining the percent increases to be applied pursuant to this section, Metro shall rely on the list published by the Oregon Department of General Services, and Metro shall not incur any liability to any bidder by relying on such list.”

07 60 00 Metal Roofing, Flashing and Sheet Metal

Paragraph 2.01 C:

DELETE in its entirety and **REPLACE** with the following:

“C. Roof and Wall Panels:

1. Roof and Wall Panels: 22 ga. by 16 inches wide, 2 inch (minimum) high standing seam with no striations. Provide and install using concealed clip fasteners.
 - a. AEP Span Lock
2. Metal Coating: 0.2-mil thick corrosion-resistant primer and a 0.8-mil thick finish coat of Polyvinylidene Fluoride (PVDF), full 70 percent Kynar 500/Hylar 5000 for a total 1.0-mil dry film thickness with a specular gloss of 10 to 15 percent when tested in accordance with ASTM D523 at 60 O.C.
 - a. Color to be one of the following:
 - 1) AEP “Cool” Zactique II
 - 2) Metal Sales: Mistique Plus
3. ASTM A792, UL 580, ASTM E1592, and UL 90 wind uplift requirements.
4. Provide matching flashings.
5. Provide matching drip flashing at gutter transitions”

END OF ADDENDUM NO.2