



**ADDENDUM NUMBER TWO
RFB 13-2214
Cooling Tower and Piping Replacement
PCPA – Antoinette Hatfield Hall**

Note: The following additions to Request for Bid 13-2214, hereby become part of the Request for Bid. It is essential that all prospective Bidders note the content of the Addendum.

In the interest of fairness, this information is being provided to all interested bidders.

Clarifications –

Drawings M0.1

Note 8 states to reference spec section 15010. Revised to reference Section 23 0000, 1.14 Start-Up: H.

Pump Schedule: Revise P-1, 2 voltage to 208

Cooling Tower Schedule: Revise CT-1 voltage to 208.

All other terms and conditions of this solicitation remain the same.

Issued December 6, 2012

A handwritten signature in black ink, appearing to read "Karen Slusarenko".

Karen Slusarenko
Procurement Analyst