



**ADDENDUM NUMBER ONE
RFB 13-2322**

**Tennis Building Roof Coating and Gutter Replacement
Glendoveer Golf Course**

Note: The following additions to Request for Bid 13-2322, hereby become part of the Request for Bid. It is essential that all prospective Bidders note the content of the Addendum.

In the interest of fairness, this information is being provided to all interested bidders.

Questions and Answers –

Q 1: Is the Top coat installer to be a Master or a Master Select Contractor?

A 1: The installer must have a Master Select certification.

Q 2: Can a Contractor bid the project as the Prime Contractor, if a Master Select Contractor, certified By GAF is the roofing sub contractor is installing the topcoat system ?

A 2: The prime contractor needs to have the master select certification. The prime contractor is expected to control all of the preparation of the roof and complete all steps of the application process. The coating is a only a portion of the job.

Q 3: Are the new gutters and downspouts to match the existing in size and number of downspouts?

A 3: Yes, the gutters/downspout style, size and number should match the existing.

Q 4: The bid forms have the old RFB # 13-2311, are these the correct forms to use when bidding? or will new forms be issued?

A 4: The bid forms have an incorrect number on the header starting at the Bidder's Checklist through the end of the document. It reads Tennis Building Roof Coating and Gutter Replacement – Glendoveer Golf Course Public Improvement Bid Response (RFB 13-2311) and should read Tennis Building Roof Coating and Gutter Replacement – Glendoveer Golf Course Public Improvement Bid Response (RFB 13-2322). The forms provided in the RFB document are acceptable to use when bidding.

All other terms and conditions of this solicitation remain the same.

Issued February 11, 2013

A handwritten signature in black ink, appearing to read "G. Schuster", written over a horizontal line.

Gabriele Schuster
Procurement Manager