

## Clarifications & Revisions

### SUBSTITUTION REQUESTS

1. Metro has received a substitution request for the Veris metering product and will **not** allow this product for this specific project.

### DOCUMENT REVISIONS

1. Sheet E0.01 – Electrical Schedules
  - a. For Distribution Equipment ID “MCC-H”, Contractor shall install MSTP Data Cable for P-6 and P-7 to nearest Alerton control panel. Coordinate exact requirements with the Alerton representative as noted in specification section 260913, paragraph E.
  - b. For Distribution Equipment ID “MCC-H”, remove the metering equipment for P-9 and replace with programming the existing variable frequency drive (VFD) and use VFD output data for load information.
  - c. For Distribution Equipment ID “MSA”, remove the requirement for metering for the following equipment:
    - i. CH-1
    - ii. CH-2
    - iii. CH-4Replace metering equipment with programming the existing VFD for CH-1, CH-2, and CH-4 and use VFD output data for load information. Meter for MCC-H shall remain as specified.
  - d. For Distribution Equipment “EHPQ”, remove the requirement for metering for the following equipment:
    - i. AHU-55
  - e. For Distribution Equipment “EHPA”, remove the requirement for metering for the following equipment:
    - i. AHU-45
    - ii. AHU-46
    - iii. AHU-47
    - iv. AHU-48
  - f. For Distribution Equipment “EHPB”, remove the requirement for metering for the following equipment:
    - i. SF-42
    - ii. AHU-49
    - iii. AHU-50
    - iv. AHU-51
    - v. AHU-52

# Addendum #2 / RFP 12-2055

## Wireless Communications Services - Expo

2. Sheet E6.03 – Existing Electrical One-Line Diagram
  - a. Remove metering shown at switchboard “MSA” for the following equipment:
    - i. CH-1 (see item 1.c above)
    - ii. CH-2 (see item 1.c above)
    - iii. CH-4 (see item 1.c above)
  - b. Add the note “MCC-H” to the 600A, 480Y/277V motor control center feeding miscellaneous pumps P-1, P-2,....., Control Air Compressor.
  - c. Remove metering shown at motor control center “MCC-H” for the following equipment:
    - i. P-9 (see item 1.b above)

All other terms, conditions and requirements of the RFB remain in full force.

Issued March 8, 2012



---

Josh Lipscomb  
Project Manger