



**ADDENDUM NUMBER THREE
RFB 14-2486**

Dragon Café Concessions Upgrades – Oregon Convention Center

Note: The following additions and clarifications to Request for Bid 14-2486 hereby become part of the Request for Bid. It is essential that all prospective Bidders note the content of the Addendum.

In the interest of fairness, this information is being provided to all interested bidders.

Clarifications and Additional Information:

Sheet S.1 describes the awnings as structural steel but detail 13 on ID-5.1 says that they are aluminum. What are they to be ?

Awnings are to be constructed of Steel as shown in Attachment B. Please disregard detail 13/ID 5.1 from Attachment A.

What is the intent for the existing storefront & glass? Is it to be removed during construction of the structural steel and awnings out front and then put back in after? Or to remain and be protected in some manner during construction of the entry way?


The storefront glass is to remain and be protected during construction.

The exterior wainscot corrugated metal that is to be 2-1/2" x 1/4" that is not available. Can the Contractor use 2-1/2" x 1/2" with the rusted finish?

MT-3 is to be 2-1/2" x 1/2" not x 1/4" as specified in Attachment A.

All other terms and conditions of this solicitation remain the same.

Issued October 10, 2013


Julie Hoffman, CPPB
Procurement Analyst